

Note: All fixings must be Licata approved and supplied and an allowance for a minimum of 40mm embedment into the substrate, the number of fixings is determined by the specification, location and building height in relation to the wind load and pull through calculations.

OSB/Ply Sheathing Board (by others)

Timber Batten

Fire rated Breather Membrane

Licata A1 rated FCB

MW Insulation detailed to meet required U value

SW8-R Range fixings

Raso Top 800 Basecoat Applied to 5-6mm Thickness with 160g/m² mesh

Licata approved mechanical fixing installed at a rate of 1 per m² through mesh and basecoat whilst wet with 100mm x 100mm stress patches over 140mm washer

LBS 15mm Brick Slip System

Licata S1Brick Slips Adhesive

Colour Mortar

Date: 19th July 2021	Detail Ref:	Licata Building Systems Unit 6 Hampton Business Park, Bolney Way, Twickenham TW13 6DB
Drawn by: KGW	Title:	
Checked by: RH		
Scale: NTS		
Insulated Brick Slips onto Timber Frame		
Isometric Std Drawing Brick Slips		